



June Prime Lamb
195 Harefield Road
June NSW 2663
Attention: Scott Newton

Sunday, December 10, 2023



NATA Accredited Laboratory
Number: 9597
Accredited for compliance with ISO/IEC
17025 - Testing

LABORATORY ANALYSIS REPORT

Report Number: 2311-0069

Page 1 of 2

For all enquiries related to this report please quote document number: 2311-0069

<u>Facility:</u>	<u>Order #</u>	<u>Date Analysis Commenced</u>			
		16-November-2023			
<u>Sample Type</u>	<u>Collected By</u>	<u>Date Received</u>			
Effluent	P. Paradise	16-November-2023			
<u>EAL ID</u>	<u>Client ID.</u> Date/Time sample taken	<u>Test</u>	<u>Result (units)</u>	<u>Method Reference</u>	<u>Limit of Reporting</u>
23Nov-0184	MP29 (ex DAF) 16.11.23 1.00pm	Biochemical Oxygen Demand	2440 mg/L	APHA 5210 B/4500-O G	2
		Conductivity	2330 µS/cm	APHA 2510 B	1
		Nitrogen, total	316 mg/L	* APHA 4500-Norg B + 4110 B	2
		Nitrate/Nitrite as N	0.8 mg/L	LTM-W-014	0.1
		Phosphorus, Total	70.8 mg/L	LTM-W-030	0.3
		pH	8.5 pH units	APHA 4500-H+ B	
		Total Dissolved Solids	1490 mg/L	LTM-W-035	2
		Total Kjeldahl Nitrogen	315 mg/L	LTM-W-034	2
		Total Suspended Solids	1220 mg/L	APHA 2540 D	2
23Nov-0185	MP30 (MV Bigpond) 16.11.23 1.30pm	Biochemical Oxygen Demand	81 mg/L	APHA 5210 B/4500-O G	2
		Conductivity	2960 µS/cm	APHA 2510 B	1
		Nitrogen, total	175 mg/L	* APHA 4500-Norg B + 4110 B	2
		Nitrate/Nitrite as N	34 mg/L	LTM-W-014	3
		Phosphorus, Total	62.9 mg/L	LTM-W-030	0.3
		pH	7.9 pH units	APHA 4500-H+ B	
		Total Dissolved Solids	1720 mg/L	LTM-W-035	2
		Total Kjeldahl Nitrogen	141 mg/L	LTM-W-034	2
		Total Suspended Solids	166 mg/L	APHA 2540 D	2

Note:

* NATA Accreditation does not cover the performance of this service.



**Charles Sturt
University**

**ENVIRONMENTAL AND ANALYTICAL
LABORATORIES**

Locked Bag 588
Wagga Wagga NSW 2678

Tel: +61 2 6933 2849
Fax: +61 2 6933 2477
Email: eal@csu.edu.au
<http://science-health.csu.edu.au/eal>

Junee Prime Lamb
195 Harefield Road
Junee NSW 2663
Attention: Scott Newton

Sunday, December 10, 2023



NATA Accredited Laboratory
Number: 9597
Accredited for compliance with ISO/IEC
17025 - Testing

LABORATORY ANALYSIS REPORT

Report Number: 2311-0069
Page 2 of 2

For all enquiries related to this report please quote document number: 2311-0069

<u>Facility:</u>	<u>Order #</u>	<u>Date Analysis Commenced</u>			
		16-November-2023			
<u>Sample Type</u>	<u>Collected By</u>	<u>Date Received</u>			
Effluent	P. Paradise	16-November-2023			
<u>EAL ID</u>	<u>Client ID.</u> Date/Time sample taken	<u>Test</u>	<u>Result (units)</u>	<u>Method Reference</u>	<u>Limit of Reporting</u>

Signed Michael Glazier, Laboratory Manager.

*All samples analysed as received.
All soil results are reported on a dry basis.
The EAL takes no responsibility for the end use of results within this report.
This report shall not be reproduced except in full.
This report replaces any previously issued report*

www.csu.edu.au

CRICOS Provider Numbers for Charles Sturt University are 00005F (NSW), 01947G (VIC) and 02960B (ACT). ABN: 83 878 708 551